

Determination of the filtration efficiency and the retention capacity according to NF P 90-319 § 4 with derogations

**Domestic swimming pools - Filtration groups and systems - Test method for evaluating the filtration efficiency, the retention capacity and the mechanical resistance
§4 : Filtration efficiency and retention capacity**

Sample ref. Sacs de 20 kg - batch N° 5-6-2018-2 - Glass pearl, Waterco x 3

CUSTOMER IDENTIFICATION	
<i>Company</i>	NIRVANA Chauffe Piscine
	QC G8Z 4G3 Trois-Rivières CANADA
<i>Contact</i>	Mr Martin CARON
<i>Purchase order nb</i>	P14278

IFTS REFERENCES	
<i>Purchase order nb</i>	ARC_00006372
<i>IFTS Order n.</i>	AFF_00005280
<i>Quotation n.</i>	DEV_00006563.01

Written by
Kevin BARRA

Validated and signed by
Test Manager

REVISION TABLE			
<i>Date</i>	<i>Version</i>	<i>Reason for revision</i>	<i>Revision Description</i>
17/03/2021	RA_2021_00007015	Initial release	

Confidential document prepared for the attention of NIRVANA Chauffe Piscine

This report is only related to the specified product(s). Its copy is not authorised other than in its full form.

IFTS acknowledges only the digitally certified file in pdf format, before transmission to the customer. The digital certification of the report, conducted by the Chambersign certification, remains valid indefinitely as long as the file does not undergo any change. In the event of a dispute, only the file of the digitally certified report kept by IFTS will be considered as being the authentic version.

IFTS is exonerated from liability when the validity of results may be affected by information provided by the customer. When IFTS is not in charge of the sampling step, the results only apply to the sample as received or handled.

1 - SCOPE

NATURE WORKS TECNOLOGIAS has requested IFTS (Institut de la Filtration et des Techniques Séparatives) as per purchase order number PO acc. to DEV_00006541.01 to evaluate the performance of a specified number of samples according to NF P 90-319 §4 with derogations - Domestic swimming pools - Filtration groups and systems - Test method for evaluating the filtration efficiency, the retention capacity and the mechanical resistance §4 : Filtration efficiency and retention capacity.

The data contained in the following paragraphs establishes the report of the test performed on the sample identified in paragraph 2 of this document. A separate test report is issued for any other test requested as per the purchase order. This test has been performed with qualified personnel using thoroughly selected equipments in order to comply with test conditions summarized in paragraph 3 of this document. IFTS is accredited by the COFRAC to carry out tests and perform modular activities dealt with by the ISO/IEC 17025.

2 - TEST SAMPLE

<i>Sample ref.</i>	<i>IFTS ref.</i>
Sacs de 20 kg - batch N° 5-6-2018-2 Glass pearl, Waterco x 3	ECH_00038353



Sample ref. : Sacs de 20 kg - batch N° 5-6-2018-2 - Glass pearl, Waterco x 3
supplied by NIRVANA Chauffe Piscine

3- TEST CONDITIONS

3.1 Determination of the filtration efficiency and the retention capacity

The following test conditions have been applied :

- Standard : NF P 90-319 §4 with derogations*
- Multipass circulation of contaminant
- Test liquid : Filtered water
- Temperature : 23°C
- Contaminant : specified according to ISO 12103-1 A4 (ISO CTD)
- Flow velocity : 20 m³/h.m²
- Test flow rate : 0,37 m³/h
- Test volume : 41,9 L
- Counting sizes : 1, 2, 5, 10, 20, 30, 40, 50 µm
- Test concentrations :
 - Counting step : 5 mg/L
 - Clogging step : 50 mg/L
- On line particle counting
- Test end criteria
 - Final ΔP - Initial ΔP = 500 hPa or
 - Maximal test duration as specified by the customer reached or
 - Upstream pressure

* Derogation in term of fluid circulation (IFTTS's pump instead of customer's pump in order to maintain constant flow rate)

3.2 Test rig

The main pump of the test circuit is installed upstream the tested filter

- Column size H=205 cm ; d=15,4 cm ; $\Omega=0,0186\text{m}^2$
- Filtration's beds sizes :
 - Glass pearl, Waterco : H=70 cm
 - Support layer supplied by IFTTS : H=30 cm
- Backwash procedure :
 - 5 minutes at 30 m³/h.m²
 - Resulting bed expansion : 10,7%



Fig 1. : Picture of test rig

4- TEST RESULTS

4.1 Test end criteria

	Test end criteria	Actual value	End criteria
Final ΔP - Initial ΔP (hPa)	500	0	NO
Test duration (min)	≥ 360	360	YES

4.2 Filtration performances

Retention capacity at Final ΔP (g)	Filtration ratio 80% (μm)*	Filtration efficiency 45 μm (%)*	Comments
78,6	13,67	97,86	/

*Results based on initial efficiency (see comment p.5).

4.3 Filtration performances

TEST IDENTIFICATION

Test date : 03/02/2021	Operator : ML	IFTS Number : ECH_00038353
------------------------	---------------	----------------------------

FILTER IDENTIFICATION

Sample ref. : Sacs de 20 kg - batch N° 5-6-2018-2 - Glass pearl, Waterco x3	Tool ref. :
---	-------------

OPERATING CONDITIONS

Test fluid	Type : Microfiltered water	Temperature (°C) : 23,1
Initial cleanliness level	Upstream : 157,0 > 1 µm/mL	Downstream : 193,5 > 1 µm/mL

Test contaminant	Type : ISO 12103-1 A4 (ISO CTD)	Batch n. : 14151C
-------------------------	---------------------------------	-------------------

Period	Filter test		Contaminant injection				Particle counting			
	Initial flow rate (L/min)	6,2	Flow rate (L/h)	Concentration (mg/L)			Counter	Sensor	Flow rate (mL/min)	Volume (mL)
Test volume (L)	41,91	Initial		Final	Average					
Counting	Concentration (mg/L)	4,9	10,0	197,0	168,8	182,9	PAMAS 2132	Waterviewer	25	25
Clogging	Concentration (mg/L)	53,0	10,0	2023,0	1924,0	1973,5				

Test parameters evolution (Fig. 5)

TEST RESULTS

Differential pressure at test flow rate	Filter housing (hPa) : <2	Clean assy (hPa) : 93
	Filtering media (hPa) : 93	Final filtering media (hPa) : 93

Table 1 : Clogging curve (Fig. 4)	INLET - OUTLET Pressure	Value: 93 hPa
--	-------------------------	---------------

Period n.	1	2	3	4	5					
Concentration (mg/L)	-	4,9	53,0	4,9	53,0	4,9	53,0	4,9	53,0	4,9
Test duration (min)	0	30	92	123	179	210	270	302	360	392
Differential pressure (hPa)	92	91	91	92	92	93	94	94	93	94
Injected mass (g)	0	0,9	21,3	22,3	40,7	41,6	61,0	62,0	81,1	82,1

Total injected mass :	81,1 g
Final test concentration (CF-1) :	58,9 mg/L
Non-retained mass :	2,5 g
Retention capacity :	78,6 g

Raw counting results (Fig. 1-2-3) Sample ref. Sacs de 20 kg - batch N° 5-6-2018-2 - Glass pearl, Waterco x3

Table 2 : Average filtration ratio and efficiency vs. Test period	Value: 96,92 %
--	----------------

Counting period	Particle size (µm)	> 1		> 2		> 5		> 10		> 20		> 30		> 40		> 50		> 100	
		µm	E%	µm	E%	µm	E%	µm	E%	µm	E%	µm	E%	µm	E%	µm	E%	µm	E%
Upstream initial counts		157		108,6		31,26		5,662		0,721		0,16		0,04		0,024			
1	Upstream	21201	2,001	14428	2,081	3827	2,427	471,8	3,603	49,7	10,92	12,91	27,47	4,107	45,47	1,624	43,95		
	Downstream	10595	50,03	6934	51,94	1576	58,8	130,9	72,25	4,552	90,84	0,47	96,36	0,09	97,8	0,037	97,72		
2	Upstream	Saturation of counting system																	
	Downstream																		
3	Upstream																		
	Downstream																		
4	Upstream																		
	Downstream																		
5	Upstream																		
	Downstream																		
Average	Upstream																		
	Downstream																		

During counting period 2, 3, 4, and 5, number of particles is higher than saturation level due to multipass circulation and filter efficiency.

*Note: Efficiency value is rounded to 100% when above 99.995





Fig.3 : Filtration efficiency vs. Time




Fig.4 : Clogging curve

